

DHBYN

DAKSHIN HARYANA BIJLI VITRAN NIGAM

Superintending Engineer 'OP' Circle
Mehrauli Road, Gurugram.

0124-2322437

0124-2322438

e-mail: se.gurugram@gmail.com

To:

M/s DLF Ltd.
DLF Gateway Tower, R-Block.
DLF City Phase-III,
Gurugram-122002.
E-mail: moudgil.akanksha@dlf.in.

Memo No. Ch. 20 / Drg.-PLC

Dated: 10 /01/2024

Sub:

Revise Assurance Certificate of DHBYN for Residential Group Housing Colony under NILP over an area measuring 116.29625 acres at Sector-76 & 77, Gurugram, Declared load 16095KW.

Reference your letter No. Misc/Elec./1(III) dated 28.12.2023.

In continuation to this office memo No.Ch-04/Drg.-PLC dated 22.11.2023 and power requirement of your project bearing (License No.-219 of 2023 Dated 25.10.2023 by DTCP Haryana valid upto 24.10.2028 area measuring 116.29625 acres, shall be considered from the nearest source 220/33KV S/Stn., Gurugram or any other source at the time of release your load at 33KV level or the voltage level of the applied load. The load requirement of this project would be evaluated as per DHBYN norms. However, this assurance is subject to the following conditions:-

1. Subject to availability of power and infrastructure at the time of actual release of connection.
2. Necessary charges will be got deposited by you as per latest Nigam instructions and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam/HERC Regulations.
3. The necessary infrastructure will be laid by you at your own cost. The piece of land will be provided by you for the switching station / sub-station as per instructions of the Nigam.
4. This letter will be valid till the validity of license in view of Sales Circular no. D-6/2022 issued by CE/Commercial, DHBYN, Hisar vide memo no. Ch-06/SE/C/R-16/380/Vol-I dated 10.03.2022.

10/1/24
Superintending Engineer

OP Circle-I DHBYN, Gurugram

Copy to:-

The XEN 'OP' Divn. DHBYN Manesar.